


LEGEND

D1 = 3' Min. for pipe < 12" dia

D1 = 4' Min. for pipe \geq 12" dia

D2 = Minimum Cover

W = Horizontal Separation



NOTES

- 1. Electric separation requirements are for primary electric conductors only. For service conductors see plans.
- 2. Primary electric, gas, telephone, cable TV or fiber optic lines shall not cross above a water line without written approval from the City's Water Resources Department. If this approval is obtained, a utility locator strip and ABC slurry conforming to COS Specifications Sec. 601.3.6 are required.

2372 City of Scottsdale Standard Details

APPROVED BY:

) 1 .

MINIMUM UTILITY SEPARATION REQUIREMENTS

DETAIL NO.

2372